



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8140-2032:0003
CATEGORY:	8140 - EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	SHAKERTOWN 1200 Kerron Street, Winlock, WA, 98596 Contact: Rutledge, Mark (360) 785-3501 (360) 785-3076 Email: mark@shakertown.com
DESIGN:	Shakertown® Dolly Varden Tongue & Grooved, Exterior Cedar Wall Siding, 4" and 6" nominal width, 8', 10', 12' lengths, 1" nominal thickness (11/16" true thickness) exposure siding product, Western Red Cedar and fir bonded into 7 ply panel. For horizontal or *vertical installation only. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	Compliance in accordance with Chapter 7A California Building Code.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name, model number, rating, and SFM label.
APPROVAL:	Listed as exterior siding for use in the Wildland Urban Interface areas. *Refer to listee's Installation Instruction Manual for details.
NOTES:	*Test Protocol SFM 12-7A-1

*Revision 07-24-20
VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/30/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division