



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8160-2032:0004
CATEGORY:	8160 - HORIZONTAL PROJECTION UNDERSIDE FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	SHAKERTOWN 1200 Kerron Street, Winlock, WA, 98596 Contact: Rutledge, Mark (360) 785-3501 (360) 785-3076 Email: mark@shakertown.com
DESIGN:	Shakertown® Dolly Varden Tongue & Grooved, Exterior Cedar Soffit Paneling, *lengths of 4' to 20', 1" nominal thickness (11/16" true thickness) exposure siding product, Western Red Cedar, *Hemlock and Fir bonded into 6 ply panel. For horizontal installation only. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	Tested to SFM 12-7A-3
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name, model number, rating and SFM label.
APPROVAL:	Listed as exterior under-eave soffit panels for use in the Wildland Urban Interface areas.
NOTES:	

*Rev. 11-13-23
DC



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/26/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division